

## DECLARATION OF PERFORMANCE

BASED ON THE DECREE NO. 305/2011 OF EUROPEAN PARLIAMENT AND OF THE COUNCIL

1. Special ID code of the product type:	<b>81340, 81350, 81351</b>		
2. Name of product:	<b>POLYLACK KG</b>		
3. Destination of construction product:	FIRE PROTECTION PUTTY FOR THE SEALING OF PENETRATIONS		
4. Name and address of manufacturer:	DUNAMENTI TŰZVÉDELEM ZRT. 2131 GÖD, NEMESKÉRI KISS MIKLÓS U. 33.		
5. Name and address of quality representative:	ISOCOM BT. 1022 TAHL, NEFELEJCS U. 29.		
6. System for the assessment and control of performance stability of products	MSZ EN ISO 9001:2009 U44a03v5.doc		
7. Name and accreditation number of the organization certifying the conformity of the construction product	ÉMI NAT-1-1110/2010	ÉME A-247/2006	
8. Declared performance			
<b>Basic characteristic</b>	<b>Unit of measurement</b>	<b>Data measured</b>	<b>Harmonised technical specifications</b>
Fire resistance –limit	min	EI60, EI90, EI120	MSZ EN 1366-3:2009
viscosity	rpm	–	
nonvolatile substance content	m/m%	76±3	MSZ EN ISO 3251
density	g/cm <sup>3</sup>	–	
VOC	g/l	--	
adhesive strength	N/mm <sup>2</sup>	min. 0,4	MSZ EN ISO 4624:2003

Signatory on behalf of and for the manufacturer



Tibor Sebestyén  
Executive Director

Göd, 20 June 2013

BASED ON THE DECREE NO. 305/2011 OF EUROPEAN PARLIAMENT AND OF THE COUNCIL